

**TAMILNADU FIRE - RESCUE SERVICE
NO OBJECTION CERTIFICATE**

RC No : 32 / ANR / 2021

Date : 22.02.2022

NOC No : 02/2022

Sub : Issuing of No - Objection certificate for School recognition, in the Jurisdiction of Annanagar - Fire & Rescue Station

Ref : 1. GO Ms 122 Dt : 14-09-2004 / Dept. Of School Education, Tamilnadu.

2. GO Ms 123 Dt : 14-09-2004 / Dept. Of School Education, Tamilnadu.


3. Application from Correspondent of M/S. SHRI KRISHNASWAMY VIDYASHRAM.

With reference to the above G.O and application Door no.914-a, J-block, 15th street, vaigai colony, Annanagar west, Chennai-600040. The established School M/S. SHRI KRISHNASWAMY VIDYASHRAM. The school was inspected by the station officer Annanagar Mr.K.JEYARAMAN. Concerned of this department on 21.02.2022 and then observed that all fire prevention and safety arrangements as provided in the premises found in good condition. So the department gave NOC for this school to recognition it

CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire safety systems should be maintained in Good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Hose reel system should be provided with in 6 months.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a. Building occupancy capacity should not be more than 4 people per sq.meter as per national Building code-2016.
 - b. The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c. As per Para 6.3 of the BIS standards IS 14435 : 1997 as the classrooms have only one entrance, the capacity of the classrooms shall have to be limited to 45 students.
 - d. Periodical maintenance and care should be taken to maintain all fire protection equipments.
 - e. Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City Central District at Pudupet.

Office Seal With Date



[Signature] 22.2.22

To
THE CORRESPONDENT,
M/S. SHRI KRISHNASWAMY VIDYASHRAM,
DOOR NO.914-A, J-BLOCK, 15TH STREET,
VAIGAI COLONY, ANNANAGAR WEST,
CHENNAI-600040.P

Copy to:

The District Officer (Chennai - Central),